

閲覧用記録用紙 (平成27年度)

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二酸化硫黄濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
4月 (1日～30日)																								
最		39.25	39.78		867	866		194	193		61	43		9	4		16	11		4	1		0.00	0.00
大		76.15	100.79		900	901		195	195		68	50		17	7		44	18		8	6		0.00	0.00
平		69.40	93.87		888	885		195	194		64	47		13	5		28	14		6	4		0.00	0.00
5月 (1日～31日)																								
最			88.07			882			193			42			6			11			3			0.00
大			98.61			920			195			55			9			14			5			0.00
平			92.91			904			195			49			7			13			4			0.00
6月 (1日～30日)																								
最	34.30	33.25	42.97	832	854	883	195	195	190	53	61	47	12	14	6	18	23	11	1	6	2	0.00	0.00	0.00
大	76.85	74.87	101.2	900	884	922	196	195	195	65	68	55	20	19	10	40	38	14	4	12	4	0.00	0.00	0.00
平	71.61	69.21	88.55	883	873	905	195	195	194	59	66	51	15	17	8	29	30	13	2	8	3	0.00	0.00	0.00
7月 (1日～31日)																								
最	34.12	30.18	39.08	871	856	858	195	195	194	56	60	45	14	11	8	32	16	12	2	7	2	0.00	0.00	0.00
大	79.67	77.13	99.8	897	884	913	195	195	196	62	68	55	19	19	11	40	40	15	4	11	5	0.00	0.00	0.00
平	70.35	70.91	93.24	882	871	889	195	195	195	59	64	51	16	15	10	35	29	13	3	8	3	0.00	0.00	0.00
8月 (1日～31日)																								
最	32.91		84.32	876		885	195		184	55		39	13		4	23		10	6		2	0.00		0.00
大	69.89		100.51	876		917	195		195	55		55	13		11	23		14	6		6	0.00		0.00
平	51.40		96.31	876		902	195		194	55		52	13		8	23		12	6		4	0.00		0.00
9月 (1日～30日)																								
最	66.07	33.09	43.08	846	860	879	195	195	194	45	60	49	11	13	4	14	27	10	1	5	4	0.00	0.00	0.00
大	75.92	72.39	99.89	898	889	912	195	195	195	57	67	55	20	15	8	38	33	15	9	8	7	0.00	0.00	0.00
平	71.68	64.91	93.83	875	873	893	195	195	195	52	63	52	16	14	6	27	30	13	4	7	5	0.00	0.00	0.00
10月 (1日～31日)																								
最	21.44	63.37		846	858		193	194		43	59		14	12		30	25		3	4		0.00	0.00	
大	75.2	71.83		892	904		195	196		61	67		18	17		43	46		12	8		0.00	0.00	
平	67.26	66.47		865	879		194	195		56	64		17	15		37	36		5	5		0.00	0.00	
11月 (1日～6日、17日～30日)																								
最	33.16	31.19	48.53	846	809	866	195	194	193	56	61	44	12	9	4	34	11	11	3	1	7	0.00	0.00	0.00
大	77.15	74.63	101.30	868	879	911	195	197	195	61	69	51	16	16	8	40	45	13	6	10	10	0.00	0.00	0.00
平	67.77	68.50	94.03	853	856	889	195	195	195	59	64	47	15	12	5	36	23	12	4	5	8	0.00	0.00	0.00
12月 (1日～29日)																								
最		31.96	44.49		870	867		195	193					9	3			12	11		6		0.00	0.00
大		74.3	99.9		892	909		195	196					15	7			27	15		5	11		0.00
平		65.60	95.30		882	885		195	195					12	5			20	13		3	7		0.00
1月 (5日～31日)																								
最		31.42	37.23		861	876		195	193					4	4			18	10		1	5		0.00
大		71.45	99.74		897	922		195	195					14	7			35	15		7	6		0.00
平		63.76	94.56		881	900		195	195					8	5			26	13		4	5		0.00
2月 (1日～29日)																								
最	33.37		42.77	827		877	194		194	50		42	8		4	9		11	10		5	0.00		0.00
大	76.96		99.23	896		907	195		195	57		51	16		6	36		15	19		6	0.00		0.00
平	67.16		94.68	863		890	195		195	54		48	12		5	24		12	14		5	0.00		0.00
3月 (1日～31日)																								
最	32.28	28.70	37.50	859		848	195		193	54		20	7		2	17		11	1		1	0.00		0.00
大	75.84	28.70	99.27	901		893	195		195	61		57	18		9	36		14	15		4	0.00		0.00
平	70.09	28.70	91.03	883		873	195		194	58		51	12		8	25		13	5		3	0.00		0.00

注：・排ガス冷却設備についてはスートブロウ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃

閲覧用記録用紙（平成28年度）

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二氧化硫濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
4月(焼却日数)	(23日間)	(30日間)	(1日間)																					
最 小	32.34	60.09	43.61	848	877		194	191		51	5		15	1		29	24		1	1		0.00	0.00	
最 大	75.28	75.8	43.61	907	910		195	195		62	66		21	17		40	41		10	19		0.00	0.00	
平 均	68.99	70.70	43.61	879	891		195	195		58	60		17	12		35	33		4	11		0.00	0.00	
5月(焼却日数)	(20日間)	(31日間)																						
最 小	39.14	32.58		828	852		194	194		51	54		16	12		26	24		1	6		0.00	0.00	
最 大	77.15	75.67		910	913		195	195		67	70		22	19		39	65		13	15		0.00	0.00	
平 均	69.90	69.31		874	889		195	195		58	60		19	16		34	34		3	10		0.00	0.00	
6月(焼却日数)	(23日間)		(17日間)																					
最 小	34.14		49.28	844		855	195		192	45		49	6		8	13		12	1		6	0.00		0.00
最 大	75.61		99.76	916		907	195		195	60		55	16		12	36		15	7		9	0.00		0.00
平 均	68.56		94.18	879		885	195		195	53		53	11		10	24		13	3		7	0.00		0.00
7月(焼却日数)	(31日間)		(24日間)																					
最 小	29.70		42.39	848		851	195		194	46		46	3		6	10		11	1		6	0.00		0.00
最 大	76.02		99.86	889		901	195		195	57		54	10		11	26		16	8		10	0.00		0.00
平 均	68.61		92.21	872		872	195		195	51		50	7		8	18		13	4		8	0.00		0.00
8月(焼却日数)	(4日間)		(31日間)																					
最 小	36.00		90.69	848		845	195		195	47		47	5		5	16		11	4		6	0.00		0.00
最 大	72.73		99.67	867		894	195		195	52		56	6		9	19		14	5		9	0.00		0.00
平 均	62.89		96.39	857		873	195		195	49		51	6		7	17		13	4		7	0.00		0.00
9月(焼却日数)	(21日間)		(20日間)																					
最 小	34.00		42.63	856		852	192		195	47		42	3		3	14		10	4		5	0.00		0.00
最 大	73.24		99.88	902		896	195		195	53		52	8		7	27		15	7		11	0.00		0.00
平 均	68.49		92.04	880		871	194		195	50		46	6		5	21		12	5		7	0.00		0.00
10月(焼却日数)	(15日間)		(31日間)																					
最 小	34.74		84.17	876		855	195		193	53		43	9		4	15		11	8		3	0.00		0.00
最 大	70.53		99.81	909		890	195		195	57		54	13		9	23		16	16		6	0.00		0.00
平 均	64.34		93.66	896		878	195		195	55		49	11		6	19		12	11		4	0.00		0.00
11月(焼却日数)	(10日間)		(20日間)																					
最 小	37.95		36.34	856		877	195		194	45		45	8		4	14		10	9		3	0.00		0.00
最 大	75.77		99.89	885		895	195		195	50		54	15		7	23		13	12		4	0.00		0.00
平 均	67.55		92.65	871		886	195		195	48		51	11		6	18		12	11		3	0.00		0.00
12月(焼却日数)	(15日間)		(29日間)																					
最 小	26.18		73.03	856		879	195		193	46		47	5		4	12		10	10		3	0.00		0.00
最 大	73.78		98.74	887		913	195		195	56		55	13		7	26		13	14		6	0.00		0.00
平 均	64.53		93.19	870		893	195		195	50		51	10		6	20		12	12		4	0.00		0.00
1月(焼却日数)		(8日間)	(27日間)																					
最 小		35.42	46.91		832	876		195	195	46.91		19	49		1	4		6	10		7	2	0.00	0.00
最 大		70.51	99.60		893	915		196	195	48		54	5		10	5		17	13		14	3	0.00	0.00
平 均		63.03	94.08		871	899		195	195	47		34	51		3	5		12	11		11	3	0.00	0.00
2月(焼却日数)		(13日間)	(28日間)																					
最 小		28.95	88.09		859	885		194	195	47		47	48		2	4		11	10		10	2	0.00	0.00
最 大		73.27	99.48		903	912		195	195	52		54	8		10	8		18	13		17	6	0.00	0.00
平 均		60.27	95.69		885	900		195	195	49		49	52		6	5		15	12		13	3	0.00	0.00
3月(焼却日数)	(12日間)		(24日間)																					
最 小	27.44		43.75	854		881	194		195	21		47	4		2	6		10	11		2	0.00		0.00
最 大	73.05		99.82	878		910	195		195	59		56	14		6	32		13	28		4	0.00		0.00
平 均	63.96		95.67	866		894	195		195	54		50	9		5	23		12	19		3	0.00		0.00

注：・排ガス冷却設備についてはスートブロウ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃
 ・最少とは焼却炉の立上げ又は立下げ日のため焼却量は通常より少なくなります。

閲覧用記録用紙 (平成29年度)

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二酸化硫黄濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
4月(焼却日数) (19日間)			(28日間)																					
最小	31.97		42.73	855		841	193		193	53		50	5		2	18		11		8		1	0.00	0.00
最大	74.24		99.43	891		884	195		195	61		57	16		20	34		15		21		15	0.00	0.00
平均	64.93		94.52	872		869	195		195	57		53	10		7	23		13		11		5	0.00	0.00
5月(焼却日数) (31日間)	(14日間)	(6日間)																						
最小	65.35	39.87	44.15	857	843	861	194	193	195	50	43	50	8	5	4	20	22	13		3	9	5	0.00	0.00
最大	73.56	75.22	97.17	912	896	874	197	195	195	64	51	53	17	15	5	40	35	14		11	14	6	0.00	0.00
平均	69.87	69.60	87.60	888	872	869	195	194	195	58	46	51	13	10	5	29	28	13		7	11	5	0.00	0.00
6月(焼却日数) (21日間)	(30日間)																							
最小	33.11		66.58	871	871		195	194		55	43		5	8		19	17			3	5		0.00	0.00
最大	71.91	74.46		905	901		195	195		63	56		14	15		33	32			9	13		0.00	0.00
平均	64.76	70.44		890	890		195	195		58	51		9	11		24	22			5	8		0.00	0.00
7月(焼却日数) (31日間)	(31日間)																							
最小	61.43	64.37		833	871		195	194		53	46		6	8		17	17			2	7		0.00	0.00
最大	69.06	73.43		895	909		195	195		62	58		12	12		30	31			10	14		0.00	0.00
平均	66.28	69.27		873	891		195	195		59	52		9	10		23	22			5	9		0.00	0.00
8月(焼却日数) (16日間)	(31日間)																							
最小	29.13		32.83	849	861		193	193		58	50		6	4		23	19			5	6		0.00	0.00
最大	73.63	73.71		902	892		195	195		68	59		11	10		34	33			12	12		0.00	0.00
平均	63.80	68.77		871	875		195	195		61	54		8	7		27	27			8	8		0.00	0.00
9月(焼却日数) (30日間)	(23日間)																							
最小	67.49	33.88		857	841		194	194		64	44		5	3		20	23			8	4		0.00	0.00
最大	74.46	72.03		910	883		195	195		70	59		19	24		42	33			20	9		0.00	0.00
平均	70.87	67.18		888	861		195	195		68	53		9	10		28	27			14	6		0.00	0.00
10月(焼却日数) (31日間)	(31日間)																							
最小	64.43	65.86		843	848		193	194		58	54		2	6		21	21			7	2		0.00	0.00
最大	75.27	74.34		900	894		195	195		72	65		11	19		40	33			22	8		0.00	0.00
平均	69.94	69.69		866	868		195	195		65	60		6	10		29	27			13	4		0.00	0.00
11月(焼却日数) (12日間)	(20日間)																							
最小	29.24	30.73		866	859		193	191		61	46		5	2		27	21			13	2		0.00	0.00
最大	70.14	70.48		898	903		195	195		68	66		10	19		38	43			22	6		0.00	0.00
平均	58.51	63.84		881	884		194	194		65	58		8	11		35	32			16	4		0.00	0.00
12月(焼却日数) (29日間)	(31日間)																							
最小	27.39	59.80		879	861		194	194		50	39		3	4		20	20			12	6		0.00	0.00
最大	70.82	69.45		914	901		195	195		67	53		10	9		31	34			25	10		0.00	0.00
平均	64.31	65.55		898	882		195	195		58	49		6	7		26	27			19	7		0.00	0.00
1月(焼却日数) (8日間)	(31日間)	(18日間)																						
最小	30.69	60.61	36.61	871	841	852	195	194	190	49	47	26	3	3	4	17	12	7		13	5	1	0.00	0.00
最大	68.78	79.22	99.02	884	900	918	195	196	195	55	54	57	6	9	9	25	30	17		17	7	7	0.00	0.00
平均	58.60	68.66	91.57	877	878	893	195	195	194	52	50	53	5	6	6	20	20	14		15	6	5	0.00	0.00
2月(焼却日数) (8日間)	(28日間)																							
最小		29.91	88.18		845	881		195	193		47	49		2	3		12	11			7	2	0.00	0.00
最大		76.49	99.79		888	918		195	195		66	57		7	7		18	15			10	6	0.00	0.00
平均		66.70	92.88		865	898		195	195		60	55		4	5		15	13			8	3	0.00	0.00
3月(焼却日数) (10日間)		(27日間)																						
最小	31.82		45.08	864		886	195		194	48		52	1		4	15				15		2	0.00	0.00
最大	69.48		99.06	910		915	195		195	63		57	11		7	28				30		6	0.00	0.00
平均	62.72		92.10	893		902	195		195	56		54	6		6	22				22		4	0.00	0.00

注：・排ガス冷却設備についてはスートブロウ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃
 ・最少とは焼却炉の立上げ又は立下げのため焼却量は通常より少なくなります。

閲覧用記録用紙（平成30年度）

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二氧化硫濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
4月(焼却日数)	(14日間)	(25日間)	(14日間)																					
最小	29.66	35.37	40.06	864	874	884	194	190	194	52	24	52	7	3	4	22	13	11	16	12	1	0.00	0.00	0.00
最大	70.14	75.16	99.76	913	905	906	195	195	195	63	59	57	12	26	9	34	38	15	27	22	8	0.00	0.00	0.00
平均	63.92	67.41	92.36	893	893	896	195	194	195	57	48	54	11	15	7	26	22	13	20	17	5	0.00	0.00	0.00
5月(焼却日数)		(10日間)	(31日間)																					
最小		29.91	91.97		877	874		193	194		55	51		20	7		13	11		14	6		0.00	0.00
最大		71.74	99.8		908	905		195	195		62	57		27	12		24	16		21	8		0.00	0.00
平均		64.21	97.21		898	894		195	195		57	54		24	9		17	13		16	7		0.00	0.00
6月(焼却日数)	(19日間)	(12日間)	(15日間)																					
最小	31.84	38.31	47.42	838	850	878	194	192	195	53	54	52	5	22	7	13	10	10	11	12	6	0.00	0.00	0.00
最大	77.83	76.7	99.58	890	908	901	195	195	195	62	64	55	9	36	9	33	30	13	23	16	8	0.00	0.00	0.00
平均	70.40	70.51	94.54	867	883	893	195	194	195	59	58	53	7	29	8	23	20	12	14	14	7	0.00	0.00	0.00
7月(焼却日数)		(29日間)	(25日間)																					
最小		33.54	44.35		878	864		191	194		41	45		1	2		6	9		10	8		0.00	0.00
最大		73.43	99.98		914	900		195	195		57	55		34	4		34	14		17	10		0.00	0.00
平均		67.11	95.42		899	886		195	195		48	50		10	3		17	13		14	9		0.00	0.00
8月(焼却日数)	(5日間)		(31日間)																					
最小	33.20		95.42	877		869	195		195	59		44	10		2	18		11	12		7	0.00		0.00
最大	67.79		99.88	896		907	195		195	61		55	13		3	23		15	16		10	0.00		0.00
平均	59.59		97.76	885		894	195		195	60		52	12		2	20		13	14		8	0.00		0.00
9月(焼却日数)	(27日間)	(21日間)	(4日間)																					
最小	32.01	34.74	43.09	861	881	885	195	194	195	51	34	49	8	2	3	16	18	12	7	13	8	0.00	0.00	0.00
最大	73.02	74.73	99.52	908	923	907	195	195	195	63	57	56	15	17	4	34	32	15	21	25	8	0.00	0.00	0.00
平均	67.00	67.44	83.74	888	906	893	195	195	195	58	49	52	12	8	3	24	25	13	13	16	8	0.00	0.00	0.00
10月(焼却日数)																								
最小																								
最大																								
平均																								
11月(焼却日数)																								
最小																								
最大																								
平均																								
12月(焼却日数)																								
最小																								
最大																								
平均																								
1月(焼却日数)																								
最小																								
最大																								
平均																								
2月(焼却日数)																								
最小																								
最大																								
平均																								
3月(焼却日数)																								
最小																								
最大																								
平均																								

注：・排ガス冷却設備についてはスートブロウ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃
 ・最少とは焼却炉の立上げ又は立下げ日のため焼却量は通常より少なくなります。