

閲覧用記録用紙 (平成24年度)

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二酸化硫黄濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
4月 (1日~30日)																								
最小	31.28	33.01	47.02	887	873	842	192	191	194	55	57	48	5	0	1	18	10	11	9	4	11	0.00	0.00	0.00
最大	69.73	80.22	105.99	917	904	884	195	195	195	66	68	55	10	31	8	29	27	15	26	12	15	0.00	0.00	0.00
平均	63.89	69.24	94.35	901	891	868	194	194	195	61	62	52	7	15	5	21	19	12	15	7	12	0.00	0.00	0.00
5月 (1日~31日)																								
最小	9.97		93.29	821		850	194		192	58		51	6		4	13		9	5		5	0.00		0.00
最大	79.00		104.18	894		884	195		195	66		56	14		11	22		15	25		9	0.00		0.00
平均	64.30		98.99	876		864	195		195	61		54	9		8	16		13	8		6	0.00		0.00
6月 (1日~30日)																								
最小		35.49	45.75		855	849		195	194		58	50		4	6		9	9		6	5		0.00	0.00
最大		81.69	108.44		899	874		195	195		67	56		9	10		19	14		14	8		0.00	0.00
平均		73.55	99.95		873	862		195	195		63	53		7	8		14	12		9	6		0.00	0.00
7月 (1日~31日)																								
最小	31.32	35.91		865	851		195	194		52	50		7	4		14	10		5	6		0.00	0.00	
最大	78.31	82.14		893	893		195	196		62	70		14	11		23	34		15	22		0.00	0.00	
平均	71.42	73.73		881	872		195	195		57	64		10	8		18	20		7	8		0.00	0.00	
8月 (1日~31日)																								
最小	30.55		45.13	886		860	195		194	52		49	4		7	13		11	5		4	0.00		0.00
最大	76.36		108.53	909		904	195		195	61		56	8		11	15		16	9		8	0.00		0.00
平均	69.26		96.59	899		881	195		195	57		53	6		8	14		13	7		5	0.00		0.00
9月 (1日~30日)																								
最小	30.92	38.39	46.75	862	820	877	194	195	193	42	55	52	6	11	7	11	17	11	5	7	4	0.00	0.00	0.00
最大	81.46	83.16	107.50	904	882	905	196	195	195	59	60	56	18	17	11	29	28	15	23	12	7	0.00	0.00	0.00
平均	73.83	74.13	97.63	887	856	895	195	195	195	54	58	54	10	13	9	17	24	13	8	9	6	0.00	0.00	0.00
10月 (1日~31日)																								
最小	33.68	70.27		863	862		191	194		52	51		4	5		8	13		6	4		0.00	0.00	
最大	79.22	82.94		908	897		195	195		61	62		13	11		22	29		18	13		0.00	0.00	
平均	72.36	75.82		889	877		194	195		56	55		7	7		14	20		8	7		0.00	0.00	
11月 (1日~9日、20日~30日)																								
最小	33.00	34.87	51.96	888	818	865	193	188	190	53	49	46	3	0	5	9	3	13	5	6	6	0.00	0.00	0.00
最大	77.94	77.95	104.70	913	880	874	195	196	194	60	65	50	6	6	8	15	25	17	13	25	10	0.00	0.00	0.00
平均	68.52	70.45	94.92	899	861	870	194	194	192	57	56	49	5	3	6	12	14	15	8	11	7	0.00	0.00	0.00
12月 (1日~29日)																								
最小	30.25	39.16		846	850		190	191		50	46		3	2		5	8		7	4		0.00	0.00	
最大	75.33	105.28		892	904		195	195		61	53		7	9		21	21		18	7		0.00	0.00	
平均	64.62	94.36		869	879		194	194		56	50		4	6		12	15		12	6		0.00	0.00	
1月 (5日~31日)																								
最小	29.94	51.63		855	864		195	195		52	40		6	3		13	9		10	5		0.00	0.00	
最大	75.44	102.39		874	903		195	195		62	52		9	6		21	16		18	10		0.00	0.00	
平均	65.37	94.32		866	884		195	195		56	47		7	5		16	12		14	6		0.00	0.00	
2月 (1日~28日)																								
最小	26.62	84.36		812		866	196		194	21		43	6		4	6		10	77		4	0.00		0.00
最大	67.13	95.69		812		899	196		195	21		50	6		6	6		14	77		6	0.00		0.00
平均	46.88	91.22		812		879	196		195	21		48	6		5	6		12	77		5	0.00		0.00
3月 (1日~31日)																								
最小	29.63	40.45	46.38	874	834	866	195	195	194	46	50	49	5	8	6	13	17	13	5	8	5	0.00	0.00	0.00
最大	77.63	75.35	100.30	921	888	877	195	196	195	69	59	50	12	14	7	25	31	15	125	29	8	0.00	0.00	0.00
平均	68.41	69.67	80.76	902	862	873	195	195	194	64	53	50	9	11	6	19	24	14	14	13	6	0.00	0.00	0.00

注：・排ガス冷却設備についてはスートブロウ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃

閲覧用記録用紙 (平成25年度)

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二酸化硫黄濃度 SO ₂ ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm ³				
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉		
4月 (1日～30日)																										
最小		34.56	48.06		868	874			195	194				8	5			13	11			1	1		0.00	0.00
最大		78.57	104.81		906	914			195	195				19	9			31	16			9	5		0.00	0.00
平均		72.78	95.90		884	897			195	195				13	7			22	13			5	3		0.00	0.00
5月 (1日～31日)			94.6	870		874	195		193	66		47	8		6	15		10	9			3	0.00		0.00	
最小	38.87																									
最大	80.02		105.95	895		925	195		195	70		57	13		10	18		14	10			5	0.00		0.00	
平均	66.48		99.68	886		894	195		195	69		52	11		8	16		12	9			4	0.00		0.00	
6月 (1日～30日)																										
最小	36.77	40.72	43.85	847	857	871	195	195	195	59	41	46	3	4	7	11	10	11	4	7	4	4	0.00	0.00	0.00	
最大	80.16	81.94	106.71	916	897	895	195	195	195	66	59	55	13	14	9	22	24	13	7	10	5	5	0.00	0.00	0.00	
平均	73.62	75.61	96.17	887	879	882	195	195	195	63	54	50	7	9	8	15	19	12	5	8	4	4	0.00	0.00	0.00	
7月 (1日～31日)																										
最小		36.82	40.66		861	862		195	195					7	5			12	9			7	3		0.00	0.00
最大		77.12	104.8		909	896		200	195					13	10			22	15			16	12		0.00	0.00
平均		72.26	97.01		894	879		195	195					9	7			18	13			8	4		0.00	0.00
8月 (1日～31日)			93.33			869			195			37			4			10				3			0.00	
最小																										
最大			108.62			902			195			51			9			15				6			0.00	
平均			102.90			884			195			45			7			12				4			0.00	
9月 (1日～30日)																										
最小	32.30	35.56	48.36	846	873	860	195	195	195	58	54	46	4	5	6	7	14	10	4	6	4	4	0.00	0.00	0.00	
最大	79.55	78.01	108.75	911	893	903	196	195	195	72	63	53	11	8	9	20	22	14	15	10	5	5	0.00	0.00	0.00	
平均	71.55	65.55	100.35	891	884	878	195	195	195	65	59	49	6	7	7	13	18	12	7	9	4	4	0.00	0.00	0.00	
10月 (1日～31日)																										
最小	33.10	69.73		858	868		195	195		58	50		3	3		10	14		4	4			0.00	0.00		
最大	74.07	80.92		908	912		195	196		66	64		11	9		21	25		8	20			0.00	0.00		
平均	67.78	73.97		883	890		195	195		63	59		7	6		15	17		7	8			0.00	0.00		
11月 (1日～8日、19日～30日)																										
最小	29.95	59.92	7.87	865	865	805	194	195	191	60	54	46	5	4	9	10	12	7	4	6	5	0.00	0.00	0.00		
最大	72.52	74.83	99.74	904	891	920	195	195	195	65	57	56	8	7	11	17	19	14	11	10	9	0.00	0.00	0.00		
平均	64.29	71.57	86.70	885	880	900	195	195	193	62	55	52	7	5	10	14	15	14	8	8	6	0.00	0.00	0.00		
12月 (1日～29日)																										
最小	32.50	31.51	44.96	883	847	891	195	195	193	62	54	47	2	5	6	7	15	10	6	6	3	0.00	0.00	0.00		
最大	72.81	72.86	102.01	908	875	922	195	196	195	66	63	56	8	9	10	18	44	17	13	17	7	0.00	0.00	0.00		
平均	65.81	63.94	93.31	900	865	906	195	195	195	63	58	52	5	7	8	13	36	14	8	10	5	0.00	0.00	0.00		
1月 (5日～31日)																										
最小	30.18		40.04	881		897	195		193	56		46	6		5	26		13	3		2	0.00		0.00		
最大	74.54		105.32	921		924	195		195	61		54	10		7	40		18	9		5	0.00		0.00		
平均	64.70		94.67	898		912	195		195	58		51	8		6	33		14	6		4	0.00		0.00		
2月 (1日～28日)																										
最小	31.22	44.51		819	879		194	194		56	43			6	2		2	10		8	3		0.00	0.00		
最大	74.77	114.87		847	924		195	195		57	55			19	7		23	23		27	6		0.00	0.00		
平均	62.46	99.87		833	903		195	195		57	50			13	4		15	14		18	4		0.00	0.00		
3月 (1日～31日)																										
最小	31.79	33.83		834	870		193	194		48	50			12	12		34	27		5	3		0.00	0.00		
最大	76.66	81.58		911	899		195	196		56	59			18	18		45	46		18	13		0.00	0.00		
平均	66.90	74.24		878	882		194	195		53	55			16	15		39	37		9	6		0.00	0.00		

注：・排ガス冷却設備についてはスートブロウ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃

閲覧用記録用紙 (平成26年度)

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二酸化硫黄濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3						
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉				
4月 (1日～30日)																												
最小	40.34		43.41	859		851	194		190		52		48		10		11		28		12		3		4	0.00		0.00
最大	73.95		98.15	915		908	195		195		59		54		17		15		42		17		13		9	0.00		0.00
平均	69.55		89.72	899		879	195		194		56		51		14		13		34		14		7		5	0.00		0.00
5月 (1日～31日)		38.15	89.06		864	861		195	192		40	47		8	9			25	10			7	3			0.00	0.00	
最小		81.4	101.14		887	909		195	195		50	54		12	15			33	16			10	5			0.00	0.00	
最大		73.17	95.54		871	885		195	194		45	51		9	13			29	12			8	4			0.00	0.00	
平均																												
6月 (1日～30日)		31.80	68.28	48.47	853	855	872	194	194	194	40	37	45	15	1	10	25	17	14	1	5	3	0.00	0.00	0.00		0.00	0.00
最小	76.3	82.1	101.81	886	914	888	195	195	195	51	63	51	22	18	12	37	40	14	10	19	5	0.00	0.00	0.00		0.00	0.00	
最大	70.94	75.72	89.36	875	882	882	195	195	195	45	49	48	19	11	11	33	32	14	4	9	4	0.00	0.00	0.00		0.00	0.00	
平均																												
7月 (1日～31日)		33.29	33.41	47.21	870		833	195		194	39		38	13		8	23			11	3			2	0.00	0.00	0.00	
最小	77.94	33.41	99.35	907		906	195		195	47		52	20		12	40				16	7			10	0.00	0.00	0.00	
最大	73.22	33.41	94.52	886		884	195		195	43		45	17		10	31				14	5			4	0.00	0.00	0.00	
平均																												
8月 (1日～31日)			93.3			865			194				41			8				11				2				0.00
最小			102.51			914			195				54			13				15				4				0.00
最大			97.51			896			195				48			11				12				3				0.00
平均																												
9月 (1日～30日)		36.32	35.03	42.11	888	881	863	194	195	195	49	46	43	14	7	8	25	18	11	5	3	2	0.00	0.00	0.00		0.00	0.00
最小	75.92	79.41	103.60	918	922	899	195	195	195	58	66	52	20	17	11	36	40	14	8	8	8	5	0.00	0.00	0.00		0.00	0.00
最大	69.41	72.82	94.80	901	900	880	195	195	195	52	56	48	16	12	9	32	30	12	6	5	3	0.00	0.00	0.00		0.00	0.00	
平均																												
10月 (1日～31日)		32.97	70.01		875	853		194	195		42	40		12	6		25	25		5	3			0.00	0.00		0.00	
最小	78.64	79.93		915	904		195	195		56	69		18	15		40	42		12	11			0.00	0.00		0.00		
最大	69.88	75.05		892	878		195	195		51	59		15	12		31	34		7	7			0.00	0.00		0.00		
平均																												
11月 (1日～7日、18日～30日)		34.07	38.60	40.30	836	837	857	195	195	188	50	62	43	13	10	5	27	27	14	6	6	2	0.00	0.00	0.00		0.00	0.00
最小	77.84	80.37	99.66	902	890	883	195	195	193	58	70	51	17	16	11	34	41	18	15	15	5	0.00	0.00	0.00		0.00	0.00	
最大	69.08	74.73	91.38	878	874	870	195	195	191	55	65	47	14	13	7	30	34	16	9	9	3	0.00	0.00	0.00		0.00	0.00	
平均																												
12月 (1日～29日)		29.21	35.28	69.28	887	854	849	194	195	193	53	64	46	6	8	2	15	21	12	6	5	1	0.00	0.00	0.00		0.00	0.00
最小	73.57	79.53	101.45	911	872	893	195	195	195	57	69	51	13	11	6	34	31	17	12	9	4	0.00	0.00	0.00		0.00	0.00	
最大	58.73	71.44	93.84	899	865	871	195	195	194	55	66	48	10	9	4	23	26	14	9	7	3	0.00	0.00	0.00		0.00	0.00	
平均																												
1月 (5日～31日)		32.31	38.93		865	856		195	193		63	38		6	3		20	11			4	1			0.00	0.00		
最小	72.41	97.20		887	894		195	196		67	49		10	6		36	17			7	4			0.00	0.00			
最大	65.52	92.16		876	877		195	195		65	44		9	4		29	14			6	2			0.00	0.00			
平均																												
2月 (1日～28日)		23.96	86.46	860		861	194		193	55		39	4		3	19		11	2			2	0.00		0.00			
最小	78.30	101.09	892		897	195		195	195	59		49	11		6	27		15	19			17	0.00		0.00			
最大	66.10	93.16	880		878	195		195	195	57		44	9		4	23		13	7			3	0.00		0.00			
平均																												
3月 (1日～31日)		31.86	28.92	43.37	855	861	866	194	192	193	55	60	47	6	13	4	20	34	13	1	6	3	0.00	0.00	0.00		0.00	0.00
最小	78.33	72.50	94.50	911	881	876	195	195	193	63	64	48	16	16	5	45	46	14	5	20	4	0.00	0.00	0.00		0.00	0.00	
最大	71.29	64.25	80.31	891	874	871	195	194	193	59	62	48	11	15	5	34	42	13	2	12	3	0.00	0.00	0.00		0.00	0.00	
平均																												

注：・排ガス冷却設備についてはスートブロウ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃
 ・2月分の表記に誤りがありましたので訂正します

閲覧用記録用紙 (平成27年度)

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二酸化硫黄濃度 SO ₂ ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm ³			
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	
4月 (1日~30日)																									
最		39.25	39.78		867	866		194	193		61	43		9	4		16	11		4	1		0.00	0.00	
大		76.15	100.79		900	901		195	195		68	50		17	7		44	18		8	6		0.00	0.00	
平		69.40	93.87		888	885		195	194		64	47		13	5		28	14		6	4		0.00	0.00	
5月 (1日~31日)																									
最			88.07			882			193			42			6			11			3			0.00	
大			98.61			920			195			55			9			14			5			0.00	
平			92.91			904			195			49			7			13			4			0.00	
6月 (1日~30日)																									
最	34.30	33.25	42.97	832	854	883	195	195	190	53	61	47	12	14	6	18	23	11	1	6	2	0.00	0.00	0.00	
大	76.85	74.87	101.2	900	884	922	196	195	195	65	68	55	20	19	10	40	38	14	4	12	4	0.00	0.00	0.00	
平	71.61	69.21	88.55	883	873	905	195	195	194	59	66	51	15	17	8	29	30	13	2	8	3	0.00	0.00	0.00	
7月 (1日~31日)																									
最	34.12	30.18	39.08	871	856	858	195	195	194	56	60	45	14	11	8	32	16	12	2	7	2	0.00	0.00	0.00	
大	79.67	77.13	99.8	897	884	913	195	195	196	62	68	55	19	19	11	40	40	15	4	11	5	0.00	0.00	0.00	
平	70.35	70.91	93.24	882	871	889	195	195	195	59	64	51	16	15	10	35	29	13	3	8	3	0.00	0.00	0.00	
8月 (1日~31日)																									
最	32.91		84.32	876		885	195		184	55		39	13		4	23		10	6		2	0.00		0.00	
大	69.89		100.51	876		917	195		195	55		55	13		11	23		14	6		6	0.00		0.00	
平	51.40		96.31	876		902	195		194	55		52	13		8	23		12	6		4	0.00		0.00	
9月 (1日~30日)																									
最	66.07	33.09	43.08	846	860	879	195	195	194	45	60	49	11	13	4	14	27	10	1	5	4	0.00	0.00	0.00	
大	75.92	72.39	99.89	898	889	912	195	195	195	57	67	55	20	15	8	38	33	15	9	8	7	0.00	0.00	0.00	
平	71.68	64.91	93.83	875	873	893	195	195	195	52	63	52	16	14	6	27	30	13	4	7	5	0.00	0.00	0.00	
10月 (1日~31日)																									
最	21.44	63.37		846	858		193	194		43	59		14	12		30	25		3	4		0.00	0.00		
大	75.2	71.83		892	904		195	196		61	67		18	17		43	46		12	8		0.00	0.00		
平	67.26	66.47		865	879		194	195		56	64		17	15		37	36		5	5		0.00	0.00		
11月 (1日~6日、17日~30日)																									
最	33.16	31.19	48.53	846	809	866	195	194	193	56	61	44	12	9	4	34	11	11	3	1	7	0.00	0.00	0.00	
大	77.15	74.63	101.30	868	879	911	195	197	195	61	69	51	16	16	8	40	45	13	6	10	10	0.00	0.00	0.00	
平	67.77	68.50	94.03	853	856	889	195	195	195	59	64	47	15	12	5	36	23	12	4	5	8	0.00	0.00	0.00	
12月 (1日~29日)																									
最		31.96	44.49		870	867		195	193			58	38		3		12	11			6		0.00	0.00	
大		74.3	99.9		892	909		195	196			67	51		7		27	15		5	11		0.00	0.00	
平		65.60	95.30		882	885		195	195			63	45		5		20	13		3	7		0.00	0.00	
1月 (5日~31日)																									
最		31.42	37.23		861	876		195	193			51	41		4	4		18	10		1	5		0.00	0.00
大		71.45	99.74		897	922		195	195			66	54		14	7		35	15		7	6		0.00	0.00
平		63.76	94.56		881	900		195	195			59	49		8	5		26	13		4	5		0.00	0.00
2月 (1日~29日)																									
最	33.37		42.77	827		877	194		194	50		42	8		4	9		11	10		5	0.00		0.00	
大	76.96		99.23	896		907	195		195	57		51	16		6	36		15	19		6	0.00		0.00	
平	67.16		94.68	863		890	195		195	54		48	12		5	24		12	14		5	0.00		0.00	
3月 (1日~31日)																									
最	32.28	28.70	37.50	859		848	195		193	54		20	7		2	17		11	1		1	0.00		0.00	
大	75.84	28.70	99.27	901		893	195		195	61		57	18		9	36		14	15		4	0.00		0.00	
平	70.09	28.70	91.03	883		873	195		194	58		51	12		8	25		13	5		3	0.00		0.00	

注：・排ガス冷却設備についてはストロブ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃

閲覧用記録用紙 (平成28年度)

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二氧化硫濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
4月(焼却日数)	(23日間)	(30日間)	(1日間)																					
最小	32.34	60.09	43.61	848	877		194	191		51	5		15	1		29	24		1	1		0.00	0.00	
最大	75.28	75.8	43.61	907	910		195	195		62	66		21	17		40	41		10	19		0.00	0.00	
平均	68.99	70.70	43.61	879	891		195	195		58	60		17	12		35	33		4	11		0.00	0.00	
5月(焼却日数)	(20日間)	(31日間)																						
最小	39.14	32.58		828	852		194	194		51	54		16	12		26	24		1	6		0.00	0.00	
最大	77.15	75.67		910	913		195	195		67	70		22	19		39	65		13	15		0.00	0.00	
平均	69.90	69.31		874	889		195	195		58	60		19	16		34	34		3	10		0.00	0.00	
6月(焼却日数)	(23日間)		(17日間)																					
最小	34.14		49.28	844		855	195		192	45		49	6		8	13		12	1		6	0.00		0.00
最大	75.61		99.76	916		907	195		195	60		55	16		12	36		15	7		9	0.00		0.00
平均	68.56		94.18	879		885	195		195	53		53	11		10	24		13	3		7	0.00		0.00
7月(焼却日数)	(31日間)		(24日間)																					
最小	29.70		42.39	848		851	195		194	46		46	3		6	10		11	1		6	0.00		0.00
最大	76.02		99.86	889		901	195		195	57		54	10		11	26		16	8		10	0.00		0.00
平均	68.61		92.21	872		872	195		195	51		50	7		8	18		13	4		8	0.00		0.00
8月(焼却日数)	(4日間)		(31日間)																					
最小	36.00		90.69	848		845	195		195	47		47	5		5	16		11	4		6	0.00		0.00
最大	72.73		99.67	867		894	195		195	52		56	6		9	19		14	5		9	0.00		0.00
平均	62.89		96.39	857		873	195		195	49		51	6		7	17		13	4		7	0.00		0.00
9月(焼却日数)	(21日間)		(20日間)																					
最小	34.00		42.63	856		852	192		195	47		42	3		3	14		10	4		5	0.00		0.00
最大	73.24		99.88	902		896	195		195	53		52	8		7	27		15	7		11	0.00		0.00
平均	68.49		92.04	880		871	194		195	50		46	6		5	21		12	5		7	0.00		0.00
10月(焼却日数)	(15日間)		(31日間)																					
最小	34.74		84.17	876		855	195		193	53		43	9		4	15		11	8		3	0.00		0.00
最大	70.53		99.81	909		890	195		195	57		54	13		9	23		16	16		6	0.00		0.00
平均	64.34		93.66	896		878	195		195	55		49	11		6	19		12	11		4	0.00		0.00
11月(焼却日数)	(10日間)		(20日間)																					
最小	37.95		36.34	856		877	195		194	45		45	8		4	14		10	9		3	0.00		0.00
最大	75.77		99.89	885		895	195		195	50		54	15		7	23		13	12		4	0.00		0.00
平均	67.55		92.65	871		886	195		195	48		51	11		6	18		12	11		3	0.00		0.00
12月(焼却日数)	(15日間)		(29日間)																					
最小	26.18		73.03	856		879	195		193	46		47	5		4	12		10	10		3	0.00		0.00
最大	73.78		98.74	887		913	195		195	56		55	13		7	26		13	14		6	0.00		0.00
平均	64.53		93.19	870		893	195		195	50		51	10		6	20		12	12		4	0.00		0.00
1月(焼却日数)		(8日間)	(27日間)																					
最小		35.42	46.91		832	876		195	195	46.91		19	49		1	4		6	10		7	2	0.00	0.00
最大		70.51	99.60		893	915		196	195	48		54	5		10	5		17	13		14	3	0.00	0.00
平均		63.03	94.08		871	899		195	195	47		34	51		3	5		12	11		11	3	0.00	0.00
2月(焼却日数)		(13日間)	(28日間)																					
最小		28.95	88.09		859	885		194	195	47		48		2	4			11	10		10	2	0.00	0.00
最大		73.27	99.48		903	912		195	195	52		54		10	8			18	13		17	6	0.00	0.00
平均		60.27	95.69		885	900		195	195	49		52		6	5			15	12		13	3	0.00	0.00
3月(焼却日数)	(12日間)		(24日間)																					
最小	27.44		43.75	854		881	194		195	21		47	4		2	6		10	11		2	0.00		0.00
最大	73.05		99.82	878		910	195		195	59		56	14		6	32		13	28		4	0.00		0.00
平均	63.96		95.67	866		894	195		195	54		50	9		5	23		12	19		3	0.00		0.00

注：・排ガス冷却設備についてはスートブロウ噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃
 ・最少とは焼却炉の立上げ又は立下げ日のため焼却量は通常より少なくなります。

閲覧用記録用紙（平成29年度）

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二酸化硫黄濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
4月(焼却日数)	(19日間)		(28日間)																					
最 小	31.97		42.73	855		841	193		193	53		50	5		2	18		11	8		1	0.00		0.00
最 大	74.24		99.43	891		884	195		195	61		57	16		20	34		15	21		15	0.00		0.00
平 均	64.93		94.52	872		869	195		195	57		53	10		7	23		13	11		5	0.00		0.00
5月(焼却日数)	(31日間)	(14日間)	(6日間)																					
最 小	65.35	39.87	44.15	857	843	861	194	193	195	50	43	50	8	5	4	20	22	13	3	9	5	0.00	0.00	0.00
最 大	73.56	75.22	97.17	912	896	874	197	195	195	64	51	53	17	15	5	40	35	14	11	14	6	0.00	0.00	0.00
平 均	69.87	69.60	87.60	888	872	869	195	194	195	58	46	51	13	10	5	29	28	13	7	11	5	0.00	0.00	0.00
6月(焼却日数)	(21日間)	(30日間)																						
最 小	33.11		66.58	871	871		195	194	195	55	43		5	8		19	17		3	5		0.00	0.00	
最 大	71.91	74.46		905	901		195	195	195	63	56		14	15		33	32		9	13		0.00	0.00	
平 均	64.76	70.44		890	890		195	195	195	58	51		9	11		24	22		5	8		0.00	0.00	
7月(焼却日数)	(31日間)	(31日間)																						
最 小	61.43	64.37		833	871		195	194	195	53	46		6	8		17	17		2	7		0.00	0.00	
最 大	69.06	73.43		895	909		195	195	195	62	58		12	12		30	31		10	14		0.00	0.00	
平 均	66.28	69.27		873	891		195	195	195	59	52		9	10		23	22		5	9		0.00	0.00	
8月(焼却日数)	(16日間)	(31日間)																						
最 小	29.13	32.83		849	861		193	193	195	58	50		6	4		23	19		5	6		0.00	0.00	
最 大	73.63	73.71		902	892		195	195	195	68	59		11	10		34	33		12	12		0.00	0.00	
平 均	63.80	68.77		871	875		195	195	195	61	54		8	7		27	27		8	8		0.00	0.00	
9月(焼却日数)	(30日間)	(23日間)																						
最 小	67.49	33.88		857	841		194	194	195	64	44		5	3		20	23		8	4		0.00	0.00	
最 大	74.46	72.03		910	883		195	195	195	70	59		19	24		42	33		20	9		0.00	0.00	
平 均	70.87	67.18		888	861		195	195	195	68	53		9	10		28	27		14	6		0.00	0.00	
10月(焼却日数)	(31日間)	(31日間)																						
最 小	64.43	65.86		843	848		193	194	195	58	54		2	6		21	21		7	2		0.00	0.00	
最 大	75.27	74.34		900	894		195	195	195	72	65		11	19		40	33		22	8		0.00	0.00	
平 均	69.94	69.69		866	868		195	195	195	65	60		6	10		29	27		13	4		0.00	0.00	
11月(焼却日数)	(12日間)	(20日間)																						
最 小	29.24	30.73		866	859		193	191	195	61	46		5	2		27	21		13	2		0.00	0.00	
最 大	70.14	70.48		898	903		195	195	195	68	66		10	19		38	43		22	6		0.00	0.00	
平 均	58.51	63.84		881	884		194	194	194	65	58		8	11		35	32		16	4		0.00	0.00	
12月(焼却日数)	(29日間)	(31日間)																						
最 小	27.39	59.80		879	861		194	194	195	50	39		3	4		20	20		12	6		0.00	0.00	
最 大	70.82	69.45		914	901		195	195	195	67	53		10	9		31	34		25	10		0.00	0.00	
平 均	64.31	65.55		898	882		195	195	195	58	49		6	7		26	27		19	7		0.00	0.00	
1月(焼却日数)																								
最 小																								
最 大																								
平 均																								
2月(焼却日数)																								
最 小																								
最 大																								
平 均																								
3月(焼却日数)																								
最 小																								
最 大																								
平 均																								

注：・排ガス冷却設備についてはスートブロー噴霧
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃
 ・最少とは焼却炉の立上げ又は立下げ日のため焼却量は通常より少なくなります。