

閲覧用記録用紙 (平成27年度)

日付	焼却量 t/d			燃焼ガス温度 ℃			集塵器入口温度 ℃			窒素酸化物濃度 NOX ppm			二酸化硫黄濃度 SO2 ppm			塩化水素濃度 HCL ppm			一酸化炭素濃度 CO ppm			ばいじん g/Nm3		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
4月 (1日~30日)																								
最		39.25	39.78		867	866		194	193		61	43		9	4		16	11		4	1		0.00	0.00
大		76.15	100.79		900	901		195	195		68	50		17	7		44	18		8	6		0.00	0.00
平		69.40	93.87		888	885		195	194		64	47		13	5		28	14		6	4		0.00	0.00
5月 (1日~31日)																								
最			88.07			882			193			42			6			11			3			0.00
大			98.61			920			195			55			9			14			5			0.00
平			92.91			904			195			49			7			13			4			0.00
6月 (1日~30日)																								
最	34.30	33.25	42.97	832	854	883	195	195	190	53	61	47	12	14	6	18	23	11	1	6	2	0.00	0.00	0.00
大	76.85	74.87	101.2	900	884	922	196	195	195	65	68	55	20	19	10	40	38	14	4	12	4	0.00	0.00	0.00
平	71.61	69.21	88.55	883	873	905	195	195	194	59	66	51	15	17	8	29	30	13	2	8	3	0.00	0.00	0.00
7月 (1日~31日)																								
最	34.12	30.18	39.08	871	856	858	195	195	194	56	60	45	14	11	8	32	16	12	2	7	2	0.00	0.00	0.00
大	79.67	77.13	99.8	897	884	913	195	195	196	62	68	55	19	19	11	40	40	15	4	11	5	0.00	0.00	0.00
平	70.35	70.91	93.24	882	871	889	195	195	195	59	64	51	16	15	10	35	29	13	3	8	3	0.00	0.00	0.00
8月 (1日~31日)																								
最	32.91		84.32	876		885	195		184	55		39	13		4	23		10	6		2	0.00		0.00
大	69.89		100.51	876		917	195		195	55		55	13		11	23		14	6		6	0.00		0.00
平	51.40		96.31	876		902	195		194	55		52	13		8	23		12	6		4	0.00		0.00
9月 (1日~30日)																								
最	66.07	33.09	43.08	846	860	879	195	195	194	45	60	49	11	13	4	14	27	10	1	5	4	0.00	0.00	0.00
大	75.92	72.39	99.89	898	889	912	195	195	195	57	67	55	20	15	8	38	33	15	9	8	7	0.00	0.00	0.00
平	71.68	64.91	93.83	875	873	893	195	195	195	52	63	52	16	14	6	27	30	13	4	7	5	0.00	0.00	0.00
10月 (1日~31日)																								
最	21.44	63.37		846	858		193	194		43	59		14	12		30	25		3	4		0.00	0.00	
大	75.2	71.83		892	904		195	196		61	67		18	17		43	46		12	8		0.00	0.00	
平	67.26	66.47		865	879		194	195		56	64		17	15		37	36		5	5		0.00	0.00	
11月 (1日~6日、17日~30日)																								
最	33.16	31.19	48.53	846	809	866	195	194	193	56	61	44	12	9	4	34	11	11	3	1	7	0.00	0.00	0.00
大	77.15	74.63	101.30	868	879	911	195	197	195	61	69	51	16	16	8	40	45	13	6	10	10	0.00	0.00	0.00
平	67.77	68.50	94.03	853	856	889	195	195	195	59	64	47	15	12	5	36	23	12	4	5	8	0.00	0.00	0.00
12月 (1日~29日)																								
最		31.96	44.49		870	867		195	193			58	38		3		12	11		1	6		0.00	0.00
大		74.3	99.9		892	909		195	196			67	51		7		27	15		5	11		0.00	0.00
平		65.60	95.30		882	885		195	195			63	45		5		20	13		3	7		0.00	0.00
1月 (5日~31日)																								
最		31.42	37.23		861	876		195	193		51	41		4	4		18	10		1	5		0.00	0.00
大		71.45	99.74		897	922		195	195		66	54		14	7		35	15		7	6		0.00	0.00
平		63.76	94.56		881	900		195	195		59	49		8	5		26	13		4	5		0.00	0.00
2月 (1日~29日)																								
最	33.37		42.77	827		877	194		194	50		42	8		4	9		11	10		5	0.00		0.00
大	76.96		99.23	896		907	195		195	57		51	16		6	36		15	19		6	0.00		0.00
平	67.16		94.68	863		890	195		195	54		48	12		5	24		12	14		5	0.00		0.00
3月 (1日~31日)																								
最	32.28	28.70	37.50	859		848	195		193	54		20	7		2	17		11	1		1	0.00		0.00
大	75.84	28.70	99.27	901		893	195		195	61		57	18		9	36		14	15		4	0.00		0.00
平	70.09	28.70	91.03	883		873	195		194	58		51	12		8	25		13	5		3	0.00		0.00

注：・排ガス冷却設備についてはストロブ噴霧  
 ・バグフィルター(3号炉)：1サイクル 392本/4時間40分で圧縮空気による清掃  
 ・バグフィルター(1, 2号炉)：1サイクル 350本/2時間55分で圧縮空気による清掃